



July 26, 2013

Ms. Shaili Pfeiffer  
Wisconsin Department of Natural Resources  
PO Box 7921  
Madison, Wisconsin 53707-7921

RE: Waukesha Water Utility  
Groundwater Flow Modeling

Dear Ms. Pfeiffer:

As requested, RJN Environmental Services, LLC (RJN) has completed additional modeling and model documentation relative to the Waukesha Water Utility investigation in the Troy Bedrock Valley and the western Waukesha County unconfined aquifer. In our letter to you dated February 4, 2013, several items were clarified or addressed, including a discussion of how base flow reductions were calculated for the two models (the Troy Bedrock Model and the United States Geological Survey (USGS) regional model developed for the Southeastern Wisconsin Planning Commission (SEWRPC)), both of which use the MODFLOW code.

This letter addresses the following:

- Simulated drawdowns and base flow reductions in the western unconfined area with pumping rates spread among additional wells, and wells in cells containing surface water features;
- Identification on both maps and tables, of the specific streams and lakes being evaluated;
- Simulated pumping rates;
- Drawdown configuration in the western model; and
- Revising the percent reduction in flow for both the western and Troy bedrock valley models using estimated Q80 data at the point where tributaries enter the Fox River.

***Additional Western Simulations***

A limited area was identified by Waukesha Water Utilities for well construction, based on technical and economic feasibility. This area is shown on Figure 1. To the extent possible, wells were simulated within that area. Based on the area and the desire to maintain a minimum distance of ½ mile between wells, seven were simulated.

Figure 2 shows the stream segments that were evaluated. Although other streams and lakes, located farther out from the simulated new wells, incurred a reduction in base flow, the reductions were much lower than the streams shown.

Below, two simulations from the previous submittal are shown, along with a simulation with the additional wells. The simulations conducted include:

- Two wells at a total of 10 million gallons per day (MGD)
- Three wells at a total of 10 MGD
- Seven wells at a total of 10.5 MGD

As with previous simulations, the new municipal wells were simulated in model layers 11 through 16. Wells were simulated at projected needed rates, rather than approved capacities. Figure 3 and 4 show the simulated drawdown for layers 1 and 11, respectively, for the simulation of two wells at a total of 10 MGD. Figures 5 and 6 provide the same plots for a simulation of three wells at a total of 10 MGD, and Figures 7 and 8 provide the plots for a simulation of seven wells at a total of 10.5 MGD.

As the plots for layer 11 show, the model continues to simulate the drawdown centered near the northernmost well. This condition was discussed and evaluated at length with Daniel Feinstein of the USGS. The mass balance was observed for each layer in each model cell, and no significant variations occurred in the results. However, the northernmost well is situated near some cells in which portions of the sandstone aquifer are not present in some layers. Consequently, RJN concludes that the reduced number of saturated cells in the vicinity of this well results in a greater drawdown in that area.

Table 1 summarizes the maximum simulated drawdowns for layers 1 and 11 in the various scenarios. While the drawdown for layer 11 of the seven-well scenario is slightly less than in the other scenarios, the results are all comparable.

The SEWRPC model simulates rivers and lakes using the MODFLOW stream package, which calculates and estimated stream flow in model cells. The approach, therefore, taken for this modeling effort was to identify the farthest downstream cell of the individual river reaches, and report the simulated stream flow in that cell. Table 2 summarizes the base flows and base flow reductions for the selected stream segments. The simulated base flow reductions range from 3 percent to 27 percent, with no apparent benefit resulting from the additional wells.

### ***Model Calibration, Assumptions and Limitations***

Both models utilized for this work were constructed and calibrated by other parties. The Troy Bedrock Valley model was constructed by Aquifer Science & Technology, in cooperation with SEWRPC. This model was reviewed, in terms of configuration and calibration, by staff from the Wisconsin Geological and Natural History (WGNHS) and the USGS. The SEWRPC model was constructed by staff from the USGS, and reviewed by other USGS staff as well as WGNHS. Consequently, RJN assumes that the models were rigorously calibrated.



The primary assumption in RJN's efforts in both modeling scenarios is that the wells were simulated in the appropriate model layers. However, the same convention used for municipal wells in the construction of both models was followed by RJN. Consequently, the wells should have been simulated in the suitable layers. Other assumptions are inherent to modeling. These typically relate to variables that are rarely measured or defined in the field. These include variables such as the vertical flow permeability, area-wide recharge values and evapotranspiration rates. However, these parameters are typically identified during the calibration process, and are tested in sensitivity analyses. Other assumptions pertain to variables in surface water simulations. Whether using the stream or river package, parameters such as streambed thickness and streambed permeability are never well-defined, and the modeler's experience is often the guide, as well as limited published data.

Essentially, the assumptions also define the limitations. The accuracy of anything simulated by the model, whether pumping, drought conditions, or other changes to the hydrologic system are a function of the applicability of all parameters that are applied to a model. However, these limitations are minimized by rigorous calibration and sensitivity analyses.

### ***Revised Estimates for the Fox River Basin***

The Troy Bedrock Valley model was used for the simulations of the well field scenarios north of the Vernon Marsh. Unlike the SEWRPC model, the Troy Bedrock Model simulates streams using MODFLOW's river package, which simulates changes in groundwater discharge to the streams, but does not estimate stream flow.

Figure 9 shows a typical tributary section. The "Flow Estimation Location" is the position at which the WDNR flow was originally estimated. From that point is an upstream reach and a downstream reach. An assumption was made that the cumulative base flows of the model cells in the upstream reach of the base model (i.e., the model without any new wells – existing wells 11, 12 and 13 were simulated at current pumping rates) resulted in the base flow at the estimated flow location. The cumulative base flows of the model cells in the downstream reach are then added to the stream flow at the estimation location to determine the stream flow entering the Fox River.

For the simulations with the new wells, the following approach was taken. The base flows for the cells of the upstream reach were totaled, and subtracted from the cumulative base flows from the base model. The difference was then used to adjust the flow at the flow estimation point. The cumulative base flows for the downstream reach were then added to the revised flow at the flow estimation location to calculate the flow into the Fox River under the pumping scenario. To calculate the percent stream flow reduction, the Q80 values recently provided by the WDNR at the tributaries' confluence with the Fox River were used. The flow estimation locations are shown on Figure 10.

As with previous submittals, scenarios 1-1, 1-2, 2-1 and 2-2 were simulated. The well locations for these simulations are provided on Figures 11, 12, 13 and 14, respectively.



With respect to the Fox River, the average annual stream flow for the Fox River, as recorded by the USGS gauge in Waukesha was used as the starting point. To that value, the average daily discharge from the Waukesha wastewater treatment plant was added. The cumulative simulated base flows, as well as the input from the tributaries, were added to the flow, to arrive at an estimation of the Fox River discharge into the Vernon Marsh. The estimated flows are provided in Table 3.

This letter should have adequately responded to your requests for additional simulations and clarification. However, if you need anything more, please notify us.

Sincerely,

RJN ENVIRONMENTAL SERVICES, LLC

Robert J. Nauta

Hydrogeologist

